



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

April 10, 2023

Jacob Hodson  
Olsson  
1301 Burlington St, 100  
North Kansas City, MO 64116

Re: **CD-CPC-2023-00023** - A request to approve a development plan in district M1-5 (Manufacturing) and US (Underground Space) for limited manufacturing and outdoor warehousing, wholesaling, storage and freight movement on about 17 acres generally located at NE Parvin Road and N. Corrington Avenue.

Dear Jacob Hodson:

At its meeting on April 04, 2023, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is final. All conditions imposed by the Commission, if any, are available on the following page(s).

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step. If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to the next step. Conditions recommended by the Commission cannot be waived or modified by staff.

If you have any questions, please contact me at [Andrew.Clarke@kcmo.org](mailto:Andrew.Clarke@kcmo.org) or (816) 513-8821

Sincerely,

A handwritten signature in black ink that reads "Andrew Clarke".

Andrew Clarke  
Planner



## Plan Conditions

Report Date: April 10, 2023

Case Number: CD-CPC-2023-00023

Project: Midway Ford - NE Parvin + N Corrington

---

*Condition(s) by City Planning and Development Department. Contact Andrew Clarke at (816) 513-8821 / Andrew.Clarke@kcmo.org with questions.*

1. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy.
2. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
3. All signage shall conform to 88-445 and shall require a sign permit prior to installation.
4. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.
5. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with 88-425-08.

*Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.*

6. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
7. The developer shall submit a storm drainage analysis from a Missouri-licensed civil engineer to the Land Development Division, in accordance with adopted standards, including a BMP level of service analysis prior to approval and issuance of any building permits, and that the developer secure permits to construct any improvements as required by the Land Development Division prior to issuance of any certificate of occupancy.
8. The developer shall submit plans to the Land Development Division and obtain permits to construct sidewalks along the platted frontage of N Corrington Ave and to a tie-in point with the existing sidewalks. In addition, developer shall construct associated ADA ramps at the proposed entrance drives as necessary for the type of drive approach.
9. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
10. The developer shall integrate into the existing street light system any relocated existing street lights within the street right-of-way impacted by the new drive or approach entrances as required by the Land Development Division, and the relocated lights must comply with all adopted lighting standards.
11. The developer must pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.

*Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.*

12. Security gates which span across a fire access road shall provide a means for emergency operation. Electric gates shall require a siren sensor device typically referred to as a "yelp gate" (IFC-2018 § 503.6).

*Condition(s) by Parks & Recreation. Contact Richard Sanchez at (816) 513-7678 / Richard.Sanchez@kcmo.org with questions.*

13. The developer shall submit a streetscape plan with street tree planting plan per 88-425-03 for approval and permitting by the Parks & Recreation Department's Forestry Division prior to beginning work in the public right-of-way

*Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / [heather.massey@kcmo.org](mailto:heather.massey@kcmo.org) with questions.*

14. Water/Sewer Service lines shall serve only one lot or tract and shall not cross a separate lot or tract.
15. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.  
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>

*Condition(s) by Water Services Department. Contact Jerald Windsor at (816) 513-0413 / [Jerald.Windsor@kcmo.org](mailto:Jerald.Windsor@kcmo.org) with questions.*

16. 1. The maximum fire hydrant spacing is 300', the developer must submit fire hydrant (relocation/new installation) drawings prepared by a registered professional Engineer in Missouri to the main extension desk for review, acceptance and contracts per the KC Water Rules and Regulations for Water main extensions and Relocations.  
(<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Main-Extensions-Final2.pdf> )

*Condition(s) by Water Services Department. Contact Lucas Kaspar at (816) 513-2131 / [Lucas.Kaspar@kcmo.org](mailto:Lucas.Kaspar@kcmo.org) with questions.*

17. The developer shall submit a final stream buffer plan to the Land Development Division for approval prior to issuance of any building permits and obtain permits for the Stream Buffer prior to removal of any mature riparian species within the buffer zones due to construction activities on the site, in accordance with the Section 88-415 requirements.
18. The developer must grant on City approved forms, a STREAM BUFFER Easement to the City, as required by Chapter 88 and Land Development Division, prior to issuance of any stream buffer permits.
19. The developer must show the limits of the 100-year floodplain on the final plat and show the Minimum Low Opening Elevation (MLOE) of any structure on each lot that abuts a 100-year flood prone area (including detention basins and engineered surface drainage conveyances) on any plat and plan, as required by the Land Development Division.