



CITY PLAN COMMISSION

15th Floor, City Hall
414 East 12th Street
Kansas City, Missouri 64106

kcmo.gov/planning

June 20, 2024

Matthew D Kist
Kimley-Horn
1868 Walnut Street, 06-100
Kansas City, MO 64108

Re: **CD-CPC-2024-00019** - A request to approve a development plan to allow for the construction of a hotel (lodging) in district B3-3 on about 2.4 acres generally located at NW Tiffany Springs Parkway and Interstate 29.

Dear Matthew D Kist:

At its meeting on June 18, 2024, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is only a recommendation. Your request must receive final action from the City Council. All *conditions imposed by the Commission, if any, are available on the following page(s).*

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for City Council consideration.

If you have any questions, please contact me at Larisa.Chambi@kcmo.org or (816) 513-8822.

Sincerely,

A handwritten signature in cursive script that reads "Larisa Chambi".

Larisa Chambi
Lead Planner



Plan Conditions

Report Date: June 20, 2024

Case Number: CD-CPC-2024-00019

Project: LivSmart Studios KCI

Condition(s) by City Planning and Development Department. Contact Larisa Chambi at (816) 513-8822 / Larisa.Chambi@kcmo.org with questions.

1. Signage has not been reviewed with this application, all signage shall conform to 88-445 and shall require a sign permit prior to installation.
2. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with 88-425-08.
3. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.
4. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
5. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy.
6. The developer shall work with the Police Department to resolve the following remain conditions prior to ordinance request:
 - a. Provide standard operating characteristics including but not limited to: security measure, lighting, hours of operation, noise, access requirements (keycard access/code access).
 - b. Confirm addressing location on proposed structures.
 - c. Dumpster screening needs to be raised 6 inches to 1 foot from the ground on at least one side if solid screening materials are proposed.
7. The developer shall apply for and receive approval of a variance to 88-323-02-B-2, prior to certificate of occupancy. Should a variance be denied by the Board of Zoning Adjustment the developer shall revise the plans to be compliant with the Zoning and Development Code.
8. Approving a deviation to Table 120-2 (Lot and Building Standards for O and B Districts) to allow a 60' (foot) tall building.

Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

9. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, provide a copy of the Storm Water Pollution Prevention (SWPP) plan submitted to the Missouri Dept. of Natural Resources (MDNR) and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
10. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
11. The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.

Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

12. The developer shall submit a storm drainage analysis from a Missouri-licensed civil engineer to the Land Development Division, in accordance with adopted standards, including a BMP level of service analysis prior to approval and issuance of any building permits, and that the developer secure permits to construct any improvements as required by the Land Development Division prior to issuance of any certificate of occupancy.
13. The developer shall obtain the executed and recorded City approved grading, temporary construction, drainage/sewer, or any other necessary easements from the abutting property owner(s) that may be required prior to submitting any public improvements crossing properties not controlled by the developer and include said document(s) within the public improvement applications submitted for permitting
14. The developer shall submit a streetscape plan for approval and permitting by the Land Development Division prior to beginning construction of the streetscape improvements in the public right of way, and construct ADA compliant ramps at all required locations where new private drives are being added, or where existing sidewalks are modified or repaired.
15. The developer shall grant a BMP and/or Surface Drainage Easement to the City as required by the Land Development Division, prior to recording the plat or issuance of any building permits.
16. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements as may be required.
17. The developer shall pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

18. The developer shall meet the fire flow requirements as set forth in Appendix B of the project International Fire Code 2018. (IFC-2018 § 507.1)
19. Buildings equipped with a fire standpipe system shall have an operable fire hydrant within 100 feet of the Fire Department Connection (FDC). (IFC2018 § 507.5.1.1) All Fire Department Connections (FDC) shall be threaded connections, Storz connections are not allowed in the City of Kansas City, Missouri (IFC-2018 § 903.3.6; NFPA 13-2010 § 6.8.1).
20. A required fire department access roads shall be an all weather surface. (IFC-2012: § 503.2.3) Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5) Required fire department access roads shall designed to support a fire apparatus with gross axle weight of 85,000 pounds. (IFC-2018: § 503.2.3) The turning radius for fire department access roads shall be 30 feet inside and 50 feet outside radius. (IFC-2018: § 503.2.4) Shall provide fire lane signage on fire access drives.
21. Aerial Fire Apparatus access roads shall be provided for any building that is 30 feet in height or greater. Aerial Fire Apparatus Roads are a minimum 26 feet wide, at least 15 feet away from the building but not more than 30 feet from the structure. (IFC-2018 § D105).

Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.

22. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.
South of River contact - Patrick Lewis 816-513-0423
North of River contact - Pedro Colato 816-513-4892
23. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>

Condition(s) by Water Services Department. Contact Kirk Rome at (816) 513-0368 / kirk.rome@kcmo.org with questions.

24. Obtain KC Water approval of the final grading plan within the existing 24" transmission main easement along the west side of the property. The grading plan shall retain 5' min. cover and no more than 15' of cover. Follow the requirements of the existing water easement such as no structures within the easement. Storm drain pipes parallel to the water main shall be located a minimum of 10' away.

Condition(s) by Water Services Department. Contact Lucas Kaspar at (816) 513-2131 / Lucas.Kaspar@kcmo.org with questions.

25. The developer must grant a BMP Easement to the City prior to issuance of any building permits.