



CITY PLAN COMMISSION

15th Floor, City Hall
414 East 12th Street
Kansas City, Missouri 64106

kcmo.gov/planning

November 08, 2023

Justin Murray
Bell/Knott & Associates
12730 State Line Road Suite 100, Suite 100
Leawood, KS 66209

Re: **CD-CPC-2023-00154** - A request to approve a major amendment to an approved development plan to allow for a hotel in district B3-3 on about 5.1 acres generally located at NW Plaza Circle and N. Ambassador Drive.

Dear Justin Murray:

At its meeting on November 07, 2023, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is final. All conditions imposed by the Commission, if any, are available on the following page(s).

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step. If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to the next step. Conditions recommended by the Commission cannot be waived or modified by staff.

If you have any questions, please contact me at Andrew.Clarke@kcmo.org or (816) 513-8821

Sincerely,

A handwritten signature in black ink that reads "Andrew Clarke".

Andrew Clarke
Planner



Plan Conditions

Report Date: November 02, 2023

Case Number: CD-CPC-2023-00154

Project: Hulsing Hotel Addition at KCI

Condition(s) by City Planning and Development Department. Contact Andrew Clarke at (816) 513-8821 / Andrew.Clarke@kcmo.org with questions.

1. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with 88-425-08.
2. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
3. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy.
4. All signage shall conform to 88-445 and shall require a sign permit prior to installation.
5. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.

Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

6. The developer shall submit a storm drainage analysis from a Missouri-licensed civil engineer to the Land Development Division, in accordance with adopted standards, including a BMP level of service analysis prior to approval and issuance of any building permits, and that the developer secure permits to construct any improvements as required by the Land Development Division prior to issuance of any certificate of occupancy.
7. The developer shall submit a streetscape plan for approval and permitting by the Land Development Division prior to beginning construction of the streetscape improvements in the public right of way, and construct ADA compliant ramps at all required locations where new private drives are being added, or where existing sidewalks are modified or repaired.
8. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
9. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
10. The developer shall provide acceptable easements for any deep sewers where proposed fill is added or where the sewer will be further obstructed by surface improvements and that a structural analysis be provided to confirm adequate structural integrity for the proposed loading conditions of this plan, and secure permits and provide City approved executed and recorded easement prior to adding fill or constructing surface obstructions as required by Land Development Division.
11. The developer shall grant a BMP and/or Surface Drainage Easement to the City as required by the Land Development Division, prior to recording the plat or issuance of any building permits.

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

12. • The shall meet the fire flow requirements as set forth in Appendix B of the project International Fire Code 2018. (IFC-2018 § 507.1)
13. • Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
 - Fire hydrant distribution shall follow IFC-2018 Table C102.1

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

14. • Buildings equipped with a fire standpipe system shall have an operable fire hydrant within 100 feet of the Fire Department Connection (FDC). (IFC2018 § 507.5.1.1)
15. • A required fire department access roads shall be an all weather surface. (IFC-2012: § 503.2.3)
 - Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5)
 - Required fire department access roads shall designed to support a fire apparatus with gross axle weight of 85,000 pounds. (IFC-2018: § 503.2.3)
 - Shall provide fire lane signage on fire access drives.
16. • Aerial Fire Apparatus access roads shall be provided for any building that is 30 feet in height or greater. Aerial Fire Apparatus Roads are a minimum 26 feet wide, at least 15 feet away from the building but not more than 30 feet from the structure. (IFC-2018 § D105).

Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.

17. Branch service lines one-and-one-half inches and larger in diameter for domestic water services or fire protection lines shall be connected to the main by cutting in a minimum 6" branch service tee, installing three gate valves, and two solid sleeves on the main. Line valves on the main shall be the same nominal size as the main.
18. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>
19. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.
South of River contact - Bryan Wagner 816-513-0275
North of River contact - Pedro Colato 816-513-4892

Condition(s) by Water Services Department. Contact Kirk Rome at (816) 513-0368 / kirk.rome@kcmo.org with questions.

20. The developer shall upsize/replace approx. 400' of existing 6" public water main in NW 119th Terrace to 12" DIP from the new service connection east to the tee in N Ambassador Drive to provide the required domestic and fire flows to meet projected demands, and add fire hydrants as-needed to meet WSD spacing requirements. The developer must submit water main extension and public fire hydrant drawings prepared by a registered professional Engineer in Missouri to the main extension desk for review, acceptance and contracts per the KC Water Rules and Regulations for Water main extensions and Relocations.
(<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Main-Extensions-Final2.pdf>).