



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

September 20, 2023

Gretchen Blain  
Generator Studio  
1701 McGee St, 600  
Kansas City, MO 64108

Re: **CD-CPC-2023-00120** - A request to approve a development plan to allow a mixed-use building in district DX-15 on about 0.35 acres generally located at 1818 and 1822 Main Street.

Dear Gretchen Blain:

At its meeting on September 19, 2023, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

*The Commission's action is only a recommendation.* Your request must receive final action from the Council. All conditions imposed by the Commission, if any, are available on the following page(s).

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for Council consideration.

If you have any questions, please contact me at [Genevieve.Kohn@kcmo.org](mailto:Genevieve.Kohn@kcmo.org) or (816) 513-8808.

Sincerely,

A handwritten signature in cursive script that reads "Genevieve Kohn".

Genevieve Kohn  
Planner



## Plan Conditions

Report Date: September 20, 2023

Case Number: CD-CPC-2023-00120

Project: 1818 Main Apartments

---

Condition(s) by City Planning and Development Department. Contact Genevieve Kohn at (816) 513-8808 / [Genevieve.Kohn@kcmo.org](mailto:Genevieve.Kohn@kcmo.org) with questions.

1. Streetcar authority requires all tenant loading or move-in activities shall be accommodated via the alley and parking garage.
2. The developer shall coordinate with the Public Works Department and Streetcar Authority prior to applying for any building permit. Applicant shall receive approval from the Streetcar Authority regarding garbage pickup schedules to ensure there is no conflict with streetcar operations.
3. All signage shall conform to 88-445 and shall require a sign permit prior to installation.
4. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
5. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy.
6. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with 88-425-08.
7. The developer shall obtain approval of an alternative compliance lighting plan to allow to additional spillover light into the right of way prior to building permit.
8. The proposed development is located in an area where the Charles B. Wheeler Downtown Airport (MKC) height zoning restrictions apply. No structure in this area should be constructed which exceeds these restrictions.

Given the potential height and proximity of this plan to MKC, the proposed development will exceed FAR Part 77, Objects Affecting Navigable Airspace, standards. The proponent/developer has filed an on-line Form 7460-1, Notice of Proposed Construction or Alteration, for permanent vertical improvements or new structures and shall receive a Determination of No Hazard to Air Navigation from the FAA. Temporary cranes used for construction activities extending higher than the proposed top elevation of the building will need to be evaluated for compliance with FAR Part 77 standards as well. The FAA's Obstruction Evaluation/Airport Airspace Analysis (OE/AAA) website can be accessed at <https://oeaaa.faa.gov/oeaaa/external/portal.jsp>.

Aviation recommends the proponent/developer provide the FAA with a 1A survey accuracy statement assuming the highest horizontal and vertical tolerance was used for this design. This information certifies the ground elevations the developer has portrayed within the plans are to higher level of accuracy. Per OEAAA, if this accuracy statement isn't provided, an adjustment commensurate with a 50 foot vertical buffer is applied to the development. This information can be referenced at: <https://oeaaa.faa.gov/oeaaa/external/content/surveyAccuracy.jsp>

The proponent/developer is recommended to comply with Chapters 3, 4, and 5 of FAA Advisory Circular (AC) 70/7460-1, Obstruction Marking and Lighting, as amended.

KCAD is actively working with the FAA to address airspace restrictions in the River Market that will allow vertical development while at the same time ensuring airspace surfaces are maintained according to FAA criteria.

Condition(s) by City Planning and Development Department. Contact Genevieve Kohn at (816) 513-8808 / Genevieve.Kohn@kcmo.org with questions.

9. The following corrections shall be made prior to request for ordinance:
  - a. Remove incorrect landscape table from sheet C03. Revise table on sheet L01 in the "required" cell that 4 street trees are required and 2 general landscaping trees are required. Add the fee in lieu amount for streets trees of \$1,480.
  - b. There is concern about how close the lower balconies are to the awning/canopy, as well as the cutout on the awning/canopy, which defeats the purpose of the covered area. If the goal is to have natural light shine through, install some type of clear barrier. Discuss further with city staff and revise plans.
  - c. Revise FAR calculation to include all floor area (sum of all floors)

Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

10. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the disturbed area to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted prior to issuance of any building permits, and the developer secure permits to construct any improvements required by the Land Development Division prior to issuance of any certificate of occupancy.
11. The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.
12. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements as may be required.
13. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

14. • The project shall meet the fire flow requirements as set forth in Appendix B of the International Fire Code 2018. (IFC-2018 § 507.1)
15. • Buildings equipped with a fire standpipe system shall have an operable fire hydrant within 100 feet of the Fire Department Connection (FDC). (IFC2018 § 507.5.1.1)
16. • Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
  - Fire hydrant distribution shall follow IFC-2018 Table C102.1
17. • Buildings which have an occupiable floor greater than 75 feet above grade shall meet high-rise requirements ( IFC 2018 Sec 914.3)..
18. • New buildings shall have approved radio coverage for emergency responders within the building based on the existing coverage levels of the public safety communication systems utilized by the jurisdiction, measured at the exterior of the building. This section shall not require improvement of the existing public safety communication systems. (IFC 2018 510.1) and (NFPA1221)

Condition(s) by Parks & Recreation. Contact Justin Peterson at (816) 513-7599 / Justin.Peterson@kcmo.org with questions.

19. As indicated on plans, the developer shall pay money-in-lieu of parkland dedication. Fee shall be based on the 2023 parkland rate and paid prior to Certificate of Occupancy. With 118 proposed multi-family units, fee equates to \$90,935.77.

*Condition(s) by Parks & Recreation. Contact Justin Peterson at (816) 513-7599 / Justin.Peterson@kcmo.org with questions.*

20. The developer shall be responsible for payment in the amount of \$1,480 to the Tree Fund in lieu of providing the required number of street trees. Twenty-four shrubs shown on the development plan shall serve as alternative compliance to the required number of general landscaping trees per 88-425-04. This requirement shall be satisfied prior to certificate of occupancy.

*Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.*

21. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.  
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>
22. For all work under the Streetcar a Track Access Permit must be applied for with public works and the plumber must be track access certified. See <https://kcstreetcar.org/about-streetcar/track-access/> for additional information.

*Condition(s) by Water Services Department. Contact Lucas Kaspar at (816) 513-2131 / Lucas.Kaspar@kcmo.org with questions.*

23. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the disturbed area to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted, and the developer shall secure permits to construct any improvements required by the Land Development Division prior to recording the plat.
24. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements may be required.
25. The developer shall obtain any required encroachment permit for the private overflow grate inlet located in the right-of-way.