



CITY PLAN COMMISSION

15th Floor, City Hall
414 East 12th Street
Kansas City, Missouri 64106

kcmo.gov/planning

December 11, 2023

Chris Holmquist
Olsson
1301 Burlington, 100
North Kansas City, MO 64116

Re: **CD-CPC-2023-00165** - A request to approve a major amendment to an approved UR Preliminary Development in District UR (Urban Redevelopment) on about 103 acres generally located at US 169 and Barry Road.

Dear Chris Holmquist:

At its meeting on December 05, 2023, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is final. All conditions imposed by the Commission, if any, are available on the following page(s).

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step. If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to the next step. Conditions recommended by the Commission cannot be waived or modified by staff.

If you have any questions, please contact me at Andrew.Clarke@kcmo.org or (816) 513-8821

Sincerely,

A handwritten signature in black ink that reads "Andrew Clarke".

Andrew Clarke
Planner



Plan Conditions, Corrections, & Suggestions Report

Recommended To
Recommended By Staff

Report Date: November 29, 2023
Case Number: CD-CPC-2023-00165
Project: Metro North Crossing

Plan Conditions

Condition(s) by City Planning and Development Department. Contact Andrew Clarke at (816) 513-8821 / Andrew.Clarke@kcmo.org with questions.

1. The developer shall secure approval of a UR final plan from Development Management Division staff prior to building permit. (11/09/2023)
2. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy. (11/09/2023)
3. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with 88-425-08. (11/09/2023)
4. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy. (11/09/2023)
5. That Ordinance No. 210568, including all conditions provided therein, shall remain in full force and effect. (11/09/2023)
6. Signage shall comply with the Council Approved Signage Plan (Ord. No. 230414). (11/09/2023)

Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

7. The developer shall submit a new, or update previously accepted Macro Storm Drainage Study from a Missouri-licensed civil engineer to the Land Development Division for the overall development in accordance with adopted standards to address development amendments or modified conveyance systems, etc., along with providing a detailed Micro study prior to final platting or issuance of a building permit (whichever occurs first), that is in general compliance with the Macro and adopted standards, including a BMP level of service analysis, and securing permits to construct any improvements as required by the Land Development Division. (11/06/2023)
8. The arterial improvements proposed on the development plans must be reviewed and accepted by the Transportation Development Committee and the Impact Fee District Committee before an application for impact fee credits will be accepted. (11/06/2023)
9. The developer shall secure permits to extend public sanitary and storm water conveyance systems to serve all proposed lots within the development and determine adequacy of receiving systems as required by the Land Development Division, prior to recording the plat or issuance of a building permit whichever occurs first. (11/06/2023)
10. The developer must design and construct all interior public streets to City Standards, as required by Chapter 88 and the Land Development Division, including curb and gutter, storm sewers, street lights, and sidewalks. (11/06/2023)
11. The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy. (11/06/2023)
12. The developer shall submit construction plans in compliance with adopted standards for all improvements required by the traffic study approved by the Public Works Department, and shall secure permits for those improvements as required by the Land Development Division, prior to recording the plat. (11/06/2023)
13. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities. (11/06/2023)

Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.

14. The developer shall pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division. (11/06/2023)
15. The developer shall enter into a covenant agreement for the maintenance of any stormwater detention area tracts as required by the Land Development Division, prior to recording the plat. (11/06/2023)
16. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements as may be required. (11/06/2023)
17. The developer shall submit a streetscape plan for approval and permitting by the Land Development Division prior to beginning construction of the streetscape improvements in the public right of way, and construct ADA compliant ramps at all required locations where new private drives are being added, or where existing sidewalks are modified or repaired. (11/06/2023)

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

18. • The developer shall meet the fire flow requirements as set forth in Appendix B of the project International Fire Code 2018. (IFC-2018 § 507.1) Fire Water Flow (11/01/2023)
19. • Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
 - Fire hydrant distribution shall follow IFC-2018 Table C102.1 Hydrant (11/01/2023)
20. • A required fire department access roads shall be an all weather surface. (IFC-2012: § 503.2.3)
 - Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5)
 - Required fire department access roads shall designed to support a fire apparatus with gross axle weight of 85,000 pounds. (IFC-2018: § 503.2.3) Fire Department Access (11/01/2023)
21. • Aerial Fire Apparatus access roads shall be provided for any building that is 30 feet in height or greater. Aerial Fire Apparatus Roads are a minimum 26 feet wide, at least 15 feet away from the building but not more than 30 feet from the structure. (IFC-2018 § D105).
 - Buildings exceeding three (3) stories or 30 feet in height shall have at least two means of fire apparatus access. (IFC-2018: § D104.1) Fire Department Access (11/01/2023)
22. • New buildings shall have approved radio coverage for emergency responders within the building based on the existing coverage levels of the public safety communication systems utilized by the jurisdiction, measured at the exterior of the building. This section shall not require improvement of the existing public safety communication systems. (IFC 2018 510.1) and (NFPA1221) First Responder Radio Coverage (11/01/2023)
23. • The turning radius for fire department access roads shall be 30 feet inside and 50 feet outside radius. (IFC-2018: § 503.2.4) Fire Department Access (11/01/2023)

Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.

24. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.
South of River contact - Bryan Wagner 816-513-0275
North of River contact - Pedro Colato 816-513-4892 (11/03/2023)
25. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.
<https://www.kcwater.us/wp-content/uploads/2022/05/2022-Rules-and-Regulations-for-Water-Service-Lines-Final.pdf>
(11/03/2023)