



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

March 05, 2024

Robert Parks  
Weiskirch and Parks Engineers, Inc  
111 N Main, 10  
Independence, MO 64050

Re: **CLD-FnPlat-2023-00032** - A request to approve a Final Plat in District R-7.5 (Residential dash seven point five) to allow for the creation of 106 residential lots and two tracts on about 31 acres generally located at 7703 NE 108th St.

Dear Robert Parks:

At its meeting on February 20, 2024, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

*The Commission's action is only a recommendation.* Your request must receive final action from the Proceeding to next step. All conditions imposed by the Commission, if any, are available on the following page(s).

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for Proceeding to next step consideration.

If you have any questions, please contact me at [Justin.Smith@kcmo.org](mailto:Justin.Smith@kcmo.org) or (816) 513-8823.

Sincerely,

A handwritten signature in cursive script that reads "Justin Smith".

Justin Smith  
Planner

---

*Condition(s) by City Planning and Development Department. Contact Matthew Barnes at (816) 513-8817 / matthew.barnes@kcmo.org with questions.*

1. That prior to submitting documents for final approval the applicant upload Paid Tax Receipts for the most recent applicable year.
2. That prior to submitting documents for final approval the applicant update the plat to reflect the correct City Plan Commission Date, Ordinance Number, and Council Approval Date by utilizing the revised City Signature Block and insert Case No. CLD-FnPlat-2023-00032.
3. That prior to submitting documents for final approval the applicant ensure that the Title Report is current within 90 days or submits an updated Title Report.
4. That prior to recording of the Final Plat the developer shall secure approval of a project plan from the City Plan Commission for each private open space tract.
5. The developer shall secure approval of a street tree planting plan from the City Forester and plant according to said plan prior to recording the final plat.
6. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.
7. Prior to recording of the plat submit an executed original (hard copy) of the Covenant to Maintain Storm Water Detention and BMP Facilities. The covenants will be recorded simultaneously with the final plat.

*Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.*

8. The developer shall submit covenants, conditions and restrictions to the Land Development Division for review by the Law Department for approval for the maintenance of private open space and enter into a covenant agreement for the maintenance of any stormwater detention area tracts, prior to recording the plat.
9. The developer shall pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.
10. The developer shall submit a detailed Micro storm drainage analysis from a Missouri-licensed civil engineer to the Land Development Division showing compliance with the current, approved Macro study on file with the City and with current adopted standards in effect at the time of submission, including Water Quality BMP's, prior to approval and issuance of any building permits to construct improvements on the site or prior to recording the plat, whichever occurs first. The developer shall verify and/or improve downstream conveyance systems or address solutions for impacted properties due to flow contributions from the site; and that the developer construct any other improvements as required by Land Development Division as necessary to mitigate impacts from rate, volume, and quality of runoff from each proposed phase.
11. The developer shall obtain the executed and recorded City approved grading, temporary construction, drainage/sewer, or any other necessary easements from the abutting property owner(s) that may be required prior to submitting any public improvements crossing properties not controlled by the developer and include said document(s) within the public improvement applications submitted for permitting
12. The developer must design and construct all interior public streets to City Standards, as required by Chapter 88 and the Land Development Division, including curb and gutter, storm sewers, street lights, and sidewalks.
13. The developer shall integrate into the existing street light system any relocated existing street lights within the street right-of-way impacted by the new drive or approach entrances as required by the Land Development Division, and the relocated lights must comply with all adopted lighting standards.
14. The developer shall cause the area to be platted and processed in accordance with Chapter 88, Code of Ordinances of the City of Kansas City, Missouri.

*Condition(s) by City Planning and Development Department. Contact Terry Thomas at (816) 513-2510 / Terry.A.Thomas@kcmo.org with questions.*

15. The developer shall secure permits to extend public sanitary and storm water conveyance systems to serve all proposed lots within the development and determine adequacy of receiving systems as required by the Land Development Division, prior to recording the plat or issuance of a building permit whichever occurs first.
16. The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, provide a copy of the SWPP plan submitted to MDNR and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.

*Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.*

17. • Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
- Fire hydrant distribution shall follow IFC-2018 Table C102.1

*Condition(s) by Water Services Department. Contact Lucas Kaspar at (816) 513-2131 / Lucas.Kaspar@kcmo.org with questions.*

18. The developer must secure permits to extend public sanitary and storm water conveyance systems to serve all proposed lots within the development and determine adequacy of receiving systems as required by the Land Development Division and KC Water, prior to recording the plat or issuance of a building permit whichever occurs first.