



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

June 30, 2025

Brian Hochstein  
MKEC Engineering, Inc.  
11827 W 112th St, 200  
Overland Park, KS 66210

Re: **CD-CPC-2025-00059** - A request to approve a development plan in proposed District DX-5 to allow for a school, entertainment venue and spectator sports and sports and recreation, participant uses on about 5 acres generally located at W. 13th Street and Summit Street.

Dear Brian Hochstein:

At its meeting on June 18, 2025, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is final. All *conditions imposed by the Commission*, if any, *are available on the following page(s)*.

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step. If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to the next step. Conditions recommended by the Commission cannot be waived or modified by staff.

If you have any questions, please contact me at [Andrew.Clarke@kcmo.org](mailto:Andrew.Clarke@kcmo.org) or (816) 513-8821

Sincerely,

A handwritten signature in cursive script, appearing to read "Andrew Clarke".

Andrew Clarke  
Lead Planner

*Condition(s) by City Planning and Development Department. Contact Andrew Clarke at (816) 513-8821 / Andrew.Clarke@kcmo.org with questions.*

1. Pursuant to 88-570-02-F, the developer shall apply for an administrative adjustment to allow for bicycle parking to be located within the parking structure.
2. The developer shall submit an affidavit, prepared by an engineer licensed in the State of Missouri, verifying that all outdoor lighting has been installed in accordance with approved plans and that lighting levels do not exceed that shown on the approved lighting plan at the property lines prior to Certificate of Occupancy. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
3. All signage shall conform to 88-445 and shall require a sign permit prior to installation. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
4. The developer shall secure approval of a Project Plan from the City Plan Commission prior to building permit for Phase II.
5. That prior to issuance of the Certificate of Occupancy for each lot within the plat the developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved Street Tree Planting Plan and are healthy. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
6. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
7. The developer shall screen all roof and/or ground mounted mechanical and utility equipment in compliance with Section 88-425-08 of the Zoning and Development Code. This condition may be satisfied by an assigned City Planning and Development Building Inspector.
8. The applicant shall resolve the following corrections from KC Water prior to ordinance request:
  - Provide explanation for alignment of underground detention overflow running along west side of new addition and connecting to existing sewer line on the south side of the existing building and then runs north under building and connects to existing line adjacent to proposed detention area (see City GIS of existing lines running around building and under building)
  - Show manhole S030-214 and existing 12" RCP at south side of building. Identify where these flows come from and go to (see City GIS mapping)

*Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.*

9. • A required fire department access roads shall be an all weather surface. (IFC-2012: § 503.2.3) (No Grass Pavers Allowed)
10. • Required fire department access roads shall be a minimum unobstructed width of twenty (20) feet and 13 ft. 6 in clearance height. Check with Streets & Traffic (KCMO Public Works) or Missouri Department of Transportation (MODOT) that may have street planning regulations that supersede the Fire Code. (IFC-2018: § 503.2.1)
11. Fire and Life Safety Systems shall be designed for the new use.
12. • Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA 241-2013 § 8.7.2)
  - Fire hydrant distribution shall follow IFC-2018 Table C102.1
13. • The developer shall meet the fire flow requirements as set forth in Appendix B of the project International Fire Code 2018. (IFC-2018 § 507.1)
14. • Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5)

*Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.*

15. • Required fire department access roads shall be designed to support a fire apparatus with gross axle weight of 85,000 pounds. (IFC-2018: § 503.2.3)
16. • Aerial Fire Apparatus access roads shall be provided for any building that is 30 feet in height or greater. Aerial Fire Apparatus Roads are a minimum 26 feet wide, at least 15 feet away from the building but not more than 30 feet from the structure. (IFC-2018 § D105).
17. • Dead-end fire apparatus access roads in excess of 150 feet (45 720 mm) in length shall be provided with an approved area for turning around fire apparatus. (IFC-2018: § 503.2.5)
18. • The turning radius for fire department access roads shall be 30 feet inside and 50 feet outside radius. (IFC-2018: § 503.2.4)

*Condition(s) by KCPD. Contact Jeffrey Krebs at (816)651-8809 / Jeffrey.Krebs@kcmo.org with questions.*

19. Prior to issuance of a certificate of occupancy the applicant should provide a lighting study which shows the Illumination Engineering Society (IES) minimum standards of at least an average maintained foot-candle (fc) reading of 3fc in the parking lot with an average to minimum ratio of 4:1. All sidewalks/pathways need to have at least an average maintained fc of 1fc with an average to minimum ratio of 4:1 (G-1-22 Sec. 8.17). The parking garage should have an average maintained fc of 6fc on pavement with an average to minimum ratio of 4:1 and elevator/stairways should have an average maintained fc of 10fc with an average to minimum ratio of 4:1 (G-1-22 Sec. 8.8). If the existing lighting is not adequate additional lighting must be placed in order to comply with lighting standards.

*Condition(s) by Parks & Recreation. Contact Richard Sanchez at (816) 513-7678 / richard.sanchez@kcmo.org with questions.*

20. The developer shall submit plans to Parks & Recreation Department and obtain permits prior to beginning construction of streetscape improvements (including but not limited to sidewalks, curbs, gutters, streetscape elements, pedestrian and street lighting) on the Parks jurisdictional streets and construct improvements, ADA compliant ramps at all required locations where new private drives are being added, or where existing sidewalks are modified or repaired. Such improvements shall be installed per Parks & Recreation Department Standards
21. The developer shall submit a letter to the Parks and Recreation Department from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, stating the condition of the sidewalks, curbs, and gutters along boulevard/parkway, which is a Parks and Recreation jurisdictional street. The letter shall identify state of repair as defined in Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters. It shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages, as required by the Parks and Recreation Department, prior to recording the plat/issuance of any certificate of occupancy permits including temporary certificate occupancy permits.
22. Prior to construction adjacent to a Parks and Recreation jurisdictional street and/or park the developer and/or their representative shall obtain a Parks and Recreation permit for storage and restoration within a park or a Parks and Recreation jurisdictional street right-of-way including but not limited to the installation of construction trailer, stockpiling of materials or equipment, construction roads and utility cabinets/meters.

*Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / heather.massey@kcmo.org with questions.*

23. When an existing building is being renovated, is being changed in use or occupancy, or is undergoing a building addition, and the existing water service line(s) will be reused, the water service line(s) and related appurtenances shall meet the most current version of KC Water Rules and Regulations.
24. The developer shall have a water flow test done to ensure there is adequate water pressure to serve the development.  
South of River contact - Patrick Lewis (816) 513-0423  
North of River contact - David Gilyard (816) 513-4772

*Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / [heather.massey@kcmo.org](mailto:heather.massey@kcmo.org) with questions.*

25. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to issuance of Certificate of Occupancy.  
<https://www.kcwater.us/wp-content/uploads/2025/02/2025-Final-Rules-and-Regulations-for-Water-Service-Lines.pdf>

*Condition(s) by Water Services Department. Contact Kirk Rome at (816) 513-0368 / [kirk.rome@kcmo.org](mailto:kirk.rome@kcmo.org) with questions*

26. There exist public water transmission and distribution mains around the perimeter of the site. All grading within the water easements shall be approved by the KC Water Director prior to grading over these water mains.

*Condition(s) by Water Services Department. Contact Philip Taylor at / [philip.taylor@kcmo.org](mailto:philip.taylor@kcmo.org) with questions.*

27. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to KC Water evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the disturbed area to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted prior to issuance of any building permits, and the developer secure permits to construct any improvements required by KC Water prior to issuance of any certificate of occupancy.
28. The developer must obtain the executed and recorded city approved grading, temporary construction, drainage/sewer, or any other necessary easements from the abutting property owner(s) that may be required prior to submitting any public improvements crossing properties not controlled by the developer and include said document(s) within the public improvement applications submitted for permitting.
29. The owner/developer must submit plans for grading, siltation, and erosion control to KC Water for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
30. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by KC Water prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements may be required.
31. The developer must secure permits to extend public sanitary and storm water conveyance systems to serve all proposed lots within the development and determine adequacy of receiving systems as required by KC Water, prior to recording the plat or issuance of a building permit whichever occurs first.
32. The developer must grant a BMP Easement to the City as required by KC Water, prior to recording the plat or issuance of any building permits.