



## CITY PLAN COMMISSION

15th Floor, City Hall  
414 East 12th Street  
Kansas City, Missouri 64106

[kcmo.gov/planning](http://kcmo.gov/planning)

March 15, 2022

Brenton P Sells  
Taliaferro & Browne  
1020 E 8th St  
Kansas City, MO 64106

Re: **CD-CPC-2022-00010** - Samuel U. Rogers Health and Wellness Center - A request to approve a Non Residential Development in District R-0.5 (Residential 0.5) to allow for a 4-story medical office building addition (two level parking and two level office) on about 5 acres generally located at the northeast corner of E. 9th Street and Euclid Avenue creating a new pediatric wing for Samuel U. Rogers Health Center.

Dear Brenton P Sells:

At its meeting on March 15, 2022, the City Plan Commission acted as follows on the above-referenced case.

Approved with Modifications

The Commission's action is only a recommendation. Your request must receive final action from the ordinance request. All conditions imposed by the Commission, if any, are available on the following page(s).

**PLEASE READ CONDITIONS CAREFULLY** as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for ordinance request consideration.

If you have any questions, please contact me at [Olofu.Agbaji@kcmo.org](mailto:Olofu.Agbaji@kcmo.org) or (816) 513-8815.

Sincerely,

Olofu Agbaji  
Lead Planner



## Plan Conditions

Report Date: March 10, 2022

Case Number: CD-CPC-2022-00010

Project: Samuel U Rogers Housing, Health, and Wellness Campus

---

**Condition(s) by City Planning and Development Department. Contact Olofu Agbaji at (816) 513-8815 / [Olofu.Agbaji@kcmo.org](mailto:Olofu.Agbaji@kcmo.org) with questions.**

1. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that all landscaping required of the approved plan has been installed in accordance with the plan and is healthy prior to Certificate of Occupancy.
2. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.
3. That the developer continue to work with planning staff to provide adequate screening of the proposed garage to meet the requirement of Chapter 88-425 prior to ordinance request.
4. That the plan is revised to show short-term and long-term bicycle parking as required of 88-420-09.
5. As part of the public entitlement process you are required to meet the public engagement Section 88-505-12 of the City's Zoning and Development Code. Submit all required public engagement documentation to your assigned planner by 03/09/2022, via [publicengagement@kcmo.org](mailto:publicengagement@kcmo.org)

**Condition(s) by City Planning and Development Department. Contact Stacey Lowe at (816) 513-2585 / [stacey.lowe@kcmo.org](mailto:stacey.lowe@kcmo.org) with questions.**

6. The developer must obtain the executed and recorded city approved grading, temporary construction, drainage/sewer, or any other necessary easements from the abutting property owner(s) that may be required prior to submitting any public improvements crossing properties not controlled by the developer and include said document(s) within the public improvement applications submitted for permitting
7. The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements may be required.
8. The developer must enter into a covenant agreement for the maintenance of any stormwater detention area tracts as required by the Land Development Division, prior to recording the plat.
9. The developer provide acceptable easement and secure permits to relocated sanitary sewers out from under proposed buildings and structures, etc., while continuing to ensure individual service is provided to all proposed lots as required by Land Development Division prior to recording the plat or issuance of a building permit, whichever occurs first.
10. The owner/developer must submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
11. The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.
12. The developer must grant a [BMP and/or Surface Drainage Easement] to the City as required by the Land Development Division, prior to recording the plat or issuance of any building permits.

**Condition(s) by City Planning and Development Department. Contact Stacey Lowe at (816) 513-2585 / [stacey.lowe@kcmo.org](mailto:stacey.lowe@kcmo.org) with questions.**

13. The developer shall submit a Storm Drainage analysis from a Missouri-licensed civil engineer to the Land Development Division evaluating proposed improvements and impact to drainage conditions. Since this project is within a "Combined Sewer Overflow" (CSO) district, the project shall be designed to retain rainfall of 1.5 inch depth over the entire site to simulate natural runoff conditions and reduce small storm discharge to the combined sewer system. Manage the 10-year storm and 100-year storm per currently adopted APWA standards. The analysis shall be submitted, and the developer shall secure permits to construct any improvements required by the Land Development Division prior to recording the plat.
14. The developer shall cause the area to be platted and processed in accordance with Chapter 88, Code of Ordinances of the City of Kansas City, Missouri, as amended, commonly known as the Development Regulations.

**Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / [michael.schroeder@kcmo.org](mailto:michael.schroeder@kcmo.org) with questions.**

15. Buildings equipped with a fire standpipe system shall have an operable fire hydrant within 100 feet of the Fire Department Connection (FDC). (IFC2018 § 507.5.1.1)
16. Aerial Fire Apparatus access roads shall be provided for any building that is 30 feet in height or greater. Aerial Fire Apparatus Roads are a minimum 26 feet wide, at least 15 feet away from the building but not more than 30 feet from the structure. (IFC-2018 § D105).
17. The turning radius for fire department access roads is 30 feet inside and 50 feet outside radius. (IFC-2018: § 503.2.4)  
The parking lot.

**Condition(s) by Water Services Department. Contact Heather Massey at (816) 513-2111 / [heather.massey@kcmo.org](mailto:heather.massey@kcmo.org) with questions.**

18. The developer shall ensure that water and fire service lines should meet current Water Services Department Rules and Regulations. Prior to C of O.