



CITY PLAN COMMISSION

15th Floor, City Hall
414 East 12th Street
Kansas City, Missouri 64106

kcmo.gov/planning

August 07, 2023

Andy Gabbert
Renaissance Infrastructure Consulting
8653 Penrose Ln
Lenexa, KS 66219

Re: **CLD-FnPlat-2023-00018** - A request to approve a Final Plat in District MPD (Master Planned Development) on about 2 acres generally located at the southeast corner of Northwest Roanridge Road and the entrance to the Edgewood Farms Development creating one (1) lot to allow for a restaurant.

Dear Andy Gabbert:

At its meeting on August 01, 2023, the City Plan Commission acted as follows on the above-referenced case.

Approved with Conditions

The Commission's action is only a recommendation. Your request must receive final action from the City Council . All conditions imposed by the Commission, if any, are available on the following page(s).

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step.

- If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to final action.
- If revised plans are not required, your request will automatically be submitted for City Council consideration.

If you have any questions, please contact me at matthew.barnes@kcmo.org or (816) 513-8817.

Sincerely,

A handwritten signature in black ink, appearing to read "Matthew Barnes".

Matthew Barnes
Planner

The following are recommended by Matthew Barnes. For questions, contact Matthew Barnes at (816) 513-8817 or matthew.barnes@kcmo.org.

- 1) The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.
- 2) The developer shall secure approval of a street tree planting plan from the City Forester and plant according to said plan prior to recording the final plat.
- 3) Prior to recording of the Final Plat an updated Title Report which is current within 90 days and the most recent years paid tax receipt must be submitted.
- 4) Prior to recording of the final plat add the City Plan Commission approved date after the City Plan Commission has recommended approval of the plat and add the final plat ordinance number and date passed by the City Council. The case number (CLD-FnPlat-2023-00018) shall also be placed in the signature block.

The following are recommended by Michael Schroeder. For questions, contact Michael Schroeder at (816) 513-4604 or michael.schroeder@kcmo.org.

- 1) Hydrant
- 2) Fire Water Flow

The following are recommended by Terry Thomas. For questions, contact Terry Thomas at (816) 513-2510 or Terry.A.Thomas@kcmo.org.

- 1) The developer shall submit plans for grading, siltation, and erosion control to Land Development Division for review and acceptance, and secure a Site Disturbance permit for any proposed disturbance area equal to one acre or more prior to beginning any construction activities.
- 2) The developer shall submit an analysis to verify adequate capacity of the existing sewer system as required by the Land Development Division prior to issuance of a building permit to connect private system to the public sewer main and depending on adequacy of the receiving system, make other improvements as may be required.
- 3) The developer shall integrate into the existing street light system any relocated existing street lights within the street right-of-way impacted by the new drive or approach entrances as required by the Land Development Division, and the relocated lights must comply with all adopted lighting standards.
- 4) The developer shall submit a letter to the Land Development Division from a Licensed Civil Engineer, Licensed Architect, or Licensed Landscape Architect, who is registered in the State of Missouri, that identifies sidewalks, curbs, and gutters in disrepair as defined by Public Works Department's "OUT OF REPAIR CRITERIA FOR SIDEWALK, DRIVEWAY AND CURB revised 11/5/2013" and based on compliance with Chapters 56 and 64 of the Code of Ordinances for the sidewalks, curbs, and gutters where said letter shall identify the quantity and location of sidewalks, curbs, gutters that need to be constructed, repaired, or reconstructed to remedy deficiencies and/or to remove existing approaches no longer needed by this project. The developer shall secure permits to repair or reconstruct the identified sidewalks, curbs, and gutters as necessary along all development street frontages as required by the Land Development Division and prior to issuance of any certificate of occupancy permits including temporary certificate occupancy permits.
- 5) The developer shall cause the area to be platted and processed in accordance with Chapter 88, Code of Ordinances of the City of Kansas City, Missouri.
- 6) The developer shall submit plans to the Land Development Division and obtain permits to construct sidewalks along the platted frontage, of the private access road and to a tie-in point with the existing sidewalks. In addition, developer shall construct associated ADA ramps at the proposed entrance drives as necessary for the type of drive approach.
- 7) The developer shall pay impact fees as required by Chapter 39 of the City's Code of ordinances as required by the Land Development Division.
- 8) The developer shall submit verification of vertical and horizontal sight distance for the drive connection to public right-of-way to the Land Development Division and make improvements to ensure local jurisdiction and/or minimum AASHTO adequate sight distance standards are met, prior to issuance of any certificate of occupancy.
- 9) The developer shall enter into a covenant agreement for the maintenance of any stormwater detention area tracts as required by the Land Development Division, prior to recording the plat.

- 10) The developer shall submit a detailed Micro storm drainage analysis from a Missouri-licensed civil engineer to the Land Development Division showing compliance with the current, approved Macro study on file with the City and with current adopted standards in effect at the time of submission, including Water Quality BMP's, prior to approval and issuance of any building permits to construct improvements on the site or prior to recording the plat, whichever occurs first. The developer shall verify and/or improve downstream conveyance systems or address solutions for impacted properties due to flow contributions from the site; and that the developer construct any other improvements as required by Land Development Division as necessary to mitigate impacts from rate, volume, and quality of runoff from each proposed phase.