

Exhibit 3 DESCRIPTION OF AT&T EQUIPMENT INSTALLED WITHIN RACK SPACE DEFINED

4 post 23" Rack		4 post 23" Rack		4 post 23" Rack		4 post 23" Rack		4 post 23" Rack		
Pos	Rack #1	Pos	Rack #2	Pos	Rack #3	Pos	Rack #4	Pos	Rack #5	
-44		-44		-44		-44		-44		
-43	502 Power plant w/ 5 rectifiers	-43	CommScope PSU	-43	Reserved for future use	-43	Reserved for future use	-43	Reserved for future use	
-42										
-41										
-40										
-39										
-38			WCS 4 sub rack	-38						
-37				-37						
-36	Fuse Panel	-36		-36						
-35		-35	WCS 4 sub rack	-35						
-34	D2 SIAD	-34		-34						
-33	SMMI	-33		-33						
-32	FSM4/ AMIA	-32	WCS 4 sub rack	-32						
-31				-31						
-30				-30						
-29		-29		-29						
-28	GPS shelf	-28		-28						
-27		-27		-27						
-26		-26		-26						
-25		-25		-25						
-24	slide out desk	-24		-24						
-23		-23		-23						
-22	FSM4/ AMIA	-22		-22						
-21			-21		-21					
-20		-20		-20						
-19		-19		-19						
-18		-18		-18						
-17	FSM4/ AMIA	-17		-17						
-16			-16		-16					
-15			-15		-15					
-14		-14		-14						
-13		-13		-13						
-12		-12		-12						
-11		-11		-11						
-10		-10		-10						
-9		-9		-9						
-8	Batteries 1 sting	-8		-8						
-7			-7		-7					
-6			-6		-6					
-5			-5		-5					
-4			-4		-4					
-3		-3		-3						
-2		-2		-2						
-1		-1		-1						