KANSAS CITY Planning & Dev

CITY PLAN COMMISSION

15th Floor, City Hall 414 East 12th Street Kansas City, Missouri 64106

kcmo.gov/planning

June 08, 2022

Tyler A Wysong Kimley-Horn 1828 Walnut Street, 06-100 Kansas City, MO 64108

Re: **CD-CPC-2022-00066** - A request to approve a Project Plan in district MPD for Woodhaven, First Plat containing 80 single family residential lots on about 19.44 acres generally located at 3201 NW 100th St

Dear Tyler A Wysong:

At its meeting on June 07, 2022, the City Plan Commission acted as follows on the above-referenced case.

Denied

The Commission's action is final. All *conditions imposed by the Commission*, if any, *are available on the following page(s)*.

PLEASE READ CONDITIONS CAREFULLY as some or all of the conditions imposed may require action on your part to proceed to the next step. If revised plans are required, you must make such revisions and upload the revised plans prior to proceeding to the next step. Conditions recommended by the Commission cannot be waived or modified by staff.

If you have any questions, please contact me at Genevieve.Kohn@kcmo.org or (816) 513-8808

Sincerely,

Genevieve Kohn Planner

KANSAS CITY Planning & Dev

Plan Conditions

Report Date: June 08, 2022

Case Number: CD-CPC-2022-00066 Project: Woodhaven, First Plat

Condition(s) by City Planning and Development Department. Contact Genevieve Kohn at (816) 513-8808 / Genevieve.Kohn@kcmo.org with questions.

- 1. That Ordinance No. _220269_, including all conditions provided therein, shall remain in full force and effect.
- 2. Public improvements (utility extensions and streets) in tracts and/rights-of-way shall be constructed/completed prior to recording the final plat.
- 3. The developer shall submit an affidavit, completed by a landscape architect licensed in the State of Missouri, verifying that street trees have been installed in accordance with the approved street tree planting plan and are healthy prior to Certificate of Occupancy.

Condition(s) by Fire Department. Contact Michael Schroeder at (816) 513-4604 / michael.schroeder@kcmo.org with questions.

- 4. The project shall meet the fire flow requirements as set forth in Appendix B of the International Fire Code 2018. (IFC-2018 § 507.1)
- 5. Fire hydrant distribution shall follow IFC-2018 Table C102.1

Fire hydrants shall be installed and operable prior to the arrival of any combustible building materials onto the site. (IFC-2018 § 501.4 and 3312.1; NFPA -2013 § 8.7.2)

- 6. Required fire department access roads are an all weather surface. (IFC-2012: § 503.2.3)
 - Fire Department access roads shall be provided prior to construction/demolition projects begin. (IFC-2018 § 501.4 and 3310.1; NFPA 241-2013 § 7.5.5)
 - Required fire department access roads are designed to support a fire apparatus with a gross axle weight of 85,000 pounds. (IFC-2018: § 503.2.3)
- 7. Dead end fire department access road(s) in excess of 150 feet shall be provided with an approved turn around feature (i.e., cul-de-sac, hammerhead). Dead-end streets in excess of 150 feet in length resulting from a "phased" project shall provide an approved temporary turn around feature (i.e., cul-de-sac, hammerhead). (IFC-2018: § 503.2.5)